



U.S. Environmental Protection Agency  
Region X  
1200 Sixth Avenue – OCE-133  
Seattle, WA 98101

RE: NPDES Permit Number ID-002000-1

City of Salmon  
200 Main Street  
Salmon, ID 83467

In response to permit violations:

1. No Quality Assurance Plan

A QAP has been developed and is on hand at the Wastewater Treatment Plant as of 11/4/08 and has been sent to Willie Teuscher – IDEQ for review.

2. No Composite Sampler for the Treatment Plant influent.

As of 11/3/08 a new composite sampler has been received and has been installed on our influent.

Harry Shanafelt  
Wastewater Plant Operator  
City of Salmon, Idaho  
208-756-4162