



October 16, 2008

EPA
Region 10
1200 Sixth Ave, Suite 900
Seattle, WA 98101-3140

Attn: David Domingo, Compliance Officer

In response to a letter received on October 7, 2008, from EPA – (Notice of Violation)

Concerning violation 1:
Composite sampling on Influent – a composite sampler has been ordered from HACH and is forthcoming.

Concerning violation 2:
The QAP is now being developed with the help of Keller and Associates Engineering firm.

We are compiling QAP from our laboratories that do our sampling as well as our own sampling procedures.

In response to the permit violations on our TSS percent removal and TSS concentrations, we are a lagoon system and sometimes have trouble meeting the new 85% removal. We are in the process of doing a Wastewater Facility Planning Study with Keller and Associates Engineering. This study is partially funded through DEQ and will help identify some of our inadequacies.

Thank You,

Harry Shanafelt
City of Salmon
Wastewater Operator
208-756-4162
NPDES Discharge #2000-1