

<p align="center">Salmon, ID Discharge Monitoring Report Summary Jan. 2003 - Jan. 2009</p>						
TEST	Limit	Min.	Average	Max.	Units	Violations
BOD, influent		23.0	74.8	145.0	mg/L	
BOD, influent		495	818	1176	lb/day	
BOD, effluent,amt, mo. Average	626	25	88	311	lb/day	0
BOD, effluent,amt, mo. Average	30	3.0	8.2	25.0	mg/L	0
pH, effluent,min	6.5	6.30	7.19	8.10	s.u.	0
pH, effluent, max	9	6.80	7.74	9.00	s.u.	0
TSS, influent		393	867	1367	lbs/day	
TSS, influent		21.3	89.1	698.0	mg/L	
TSS, effluent	626	24	125	403	lbs/day	1
TSS, effluent	30	2.0	12.3	48.0	mg/L	2
Fecal, effluent	126	10	11	24	cts/100mL	0
Max, 7-day geo mean	406	1	48	2600	cts/100mL	3
Flow, monthly average		0.78	1.34	2.34	MGD	
% BOD removal	85	56.0	87.4	97.0	%	7
% TSS removal	85	45.0	84.2	100.0	%	10
Ammonia-N, mo. Average	-	2.51	7.59	11.60	mg/L	
Phosphorus, Mo. Average	-	1.15	3.10	22.00	mg/L	
Temp, monthly min	-	3.30	14.41	27.60	°C	
Temp, monthly max	-	4.10	14.41	26.40	°C	